



Control Valves and Actuators:
 Heating Valve For AHU-5 (CV-HC-AHU5)
 8.3m³/h; ΔP 0.43mWC; 67/47°C Capacity
 DN50/PN16 kvs: 40, 2-Way Valve with
 Proportional Valve Actuator
V5328A1096 / ML7421A3004

Heating Valve For AHU-6 / AHU-7
 (CV-HC-AHU6 / CV-HC-AHU7)
 4.4m³/h; ΔP 0.77mWC; 67/47°C Capacity
 DN32/PN16 kvs: 16, 3-Way Valve with
 Proportional Valve Actuator
V5328A1070 / ML7420A3006

Honeywell Authorized Applied Systems Partner : AEE AEE Building Automation and Control Systems Emirhan Cad., No: 52/6, 34349 Dikilitaş, İstanbul Tel : +90(212) 258 75 42 Fax : +90(212) 258 75 43 E-Mail : aee@aee.com.tr	Proje Adı / Project Name : Enka Construction and Industry Co.Inc. Moscow City Trading Center A Block Building Automation System	İlgili Cihazlar / Related Devices : AHU-5/EF-15; AHU-6/EF-16; AHU-7/EF-17	Rev. No / Rev. No : 	Tarih / Date : 25.01.2005
	Açıklama / Description : AHU-5/EF-15; AHU-6/EF-16; AHU7/EF-17 Air Handling Units for Machine Room Ventilating Automatic Control System Principle Drawing	Resim No / Drawing No : CITY B-ACD-106	İlgili Resimler / Related Drawings : CITY B-ACD-107	Yapan / Designed By : Süleyman AKDEMİR
			Rev. İzah / Rev. Desc. : For approval	Sayfa / Page : F015